


CERTIFICATE FI 29554

Our Ref. 284705-1, 276349-2, 270711-1

Product	Range of enclosures
Type	CUBO F
Trade mark	CASEMET
Certificate Holder/ Manufacturer	Casemet Oy Insinöörinkatu 1 FI-50100 MIKKELI, FINLAND
Technical information	Degree of protection (EN 60529) IP65 and IP66 Mechanical strength (EN 62262) IK09, window IK07 (-5/+80°C type FFUW) Material: steel (FFUP, FFUF, FFUW and FFPB), stainless steel (FSUP and FSPB) and acid-proof steel (FAUP and FAPB)
Other information	Empty enclosure Models included in series: See the Appendix to this Certificate
The product is certified according to the following standard(s)	EN 62208:2011
Validity	This certificate is valid until 27 June 2018 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.
Directive information	The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.
Date of issue	19 May 2016
Signature	SGS Fimko Ltd  Sixten Lökfors Project Manager

This certificate has 2 appendixes



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.